

Common Lab Violations during EH&S Inspections:

- Personnel have not completed the lab safety training course
- Hazard Assessment Form has not been completed for this year
- Missing training documentation for lab specific training
- Missing Standard Operating Procedures
- Fire diamond not updated
- Cardboard boxes stored too close to the ceiling
- Improper restraining of gas cylinders
- Not wearing lab coats/goggles when working with hazardous chemicals
- Not segregating corrosives and toxics; not labeling secondary containers
- Chemical waste containers not labeled with hazardous waste tags
- Power strips on the floor